

thePassa P360 DALI-2 S UP WH



?? ???? : 2010390 ????? ???? ???? ???? ???? ???? ???? ???? DALI-2 ????? ???? : 360 ???? ?????? ???? : 2-6 ??? 10-10000 lx : ?????? ?????
???????? IP 54: ???? ?????

???? ?????: ???? ???? ???? ????
????

[?? ???? ??????? ???? ????? ???????](#)

???

Function description

- Passive infra-red presence sensor for flush-mounted ceiling installation, DALI-2 certified
- Rectangular detection area 360°, 30 x 4,5 m, (135 m²)
- at mounting height 3 m, for corridors and storage areas, with 2 individually connectable and disconnectable detection zones
- This device provides information about presence and brightness in the form of a DALI telegram in line with IEC 62386 Part 303/304
- 3 instances for presence – detection area zone 1 + 2 / zone 1 / zone 2
- 2 mixed light measurements

- 3 instances for brightness – detection area zone 1 + 2 / zone 1 / zone 2 •
- Easy to calibrate brightness measurement •
- Test mode for checking function and detection area •
- Configurable detection sensitivity •
- Can be configured via DALI bus or remote control •

The „theSenda S“ or „theSenda B“ user remote controls can be used to dim or switch the lamps, to control the blinds, or to execute additional functions via the higher-level control •

- Ceiling installation in flush-mounted box •
- Surface-mounted installation possible with surface frame 110A (optional) •
- Area restriction with cover clips (optional) •
- „theSenda B“ app remote control (optional) and corresponding „theSenda Plug“ app (for iOS/Android) •

A Multi-Master Application Controller is required for commissioning/control and configuration. According to IEC 62386, this must include parts 101/103 and optionally 301/303/304 •

?????? ??

???? ???? ???? ??? ????? ???? ?????.

// //